



COVER: 1/4" 304 BRUSHED STAINLESS
 ENCLOSURE: #16 STAINLESS STEEL
 INSERT: 304 STAINLESS STEEL
 W/(8) SPACES FOR POWER OR LV DEVICES
 15A, 20A, 30A 3P
 GASKET: 1/8" NEOPRENE CLOSED CELL
 SIZE: 12X12X10"DEEP ±

OPTIONAL IN USE COVER



CUBS
Combined Utilities Box Systems
 5325 N. Commerce Ave, #4, Moorpark, CA 93021
 Phone: 805/532-1776, Fax: 805/529-9466

EXTERIOR FLOOR BOX WP
 WP 8g
 REV.

DATE: 3/26/08
 DRAWN BY: jgl
 DRAWING NO.: 0803020

ALL CONDUIT ENTRIES ARE MADE IN THE FIELD BY THE EC TO ACCOMMODATE FIELD REQUIREMENTS. CONDUIT ENTRY IS BELOW THE DEVICE PLATE ONLY. (SIDE ONLY)

RUBBER 2" STOPPER
 SLOTTED WITH HOLE
 TO MATCH CORD(SW)

THIS IS A CAD GENERATED DRAWING. ALL CHANGES MUST BE MADE BY THE CAD OPERATOR